



WELCOME TO THE

Electronic Annual Reporting System



LEAD SERVICE LINE REPLACEMENT

ONLY FOR COMMUNITY WATER SYSTEMS Your water system classification is: _____

Section 116885 of the California Health and Safety Code, Lead Service Lines in Public Water Systems, added to the Health and Safety Code by Senate Bill 1398 (2016) and amended by Senate Bill 427 (2017), requires all community water systems (CWS) to compile an inventory of known partial or total lead user service lines in use in its distribution system by July 1, 2018. The inventory must include all user service lines that are active and those that are reasonably expected to become active in the future. Also, Section 116885 requires that CWS identify areas that may have lead user service lines in use, and/or identify any areas within the CWS distribution system that the CWS cannot identify the material that is being used for the service line. For additional information, please visit

https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/lead_service_line_inventory_pws.shtml

If you have questions about completing this section of the report, please contact David.Pimentel@Waterboards.ca.gov or call (916) 323-0572.

Date lead service line inventory was completed (MM/DD/YYYY): _____

A. USER SERVICE LINE INVENTORY:

"User service line" means the pipe, tubing, and fittings connecting a water main to an individual water meter or service connection.

Pipe Material	Estimated Number of Service Lines	Estimated Total Length of Service Lines
A. Lead		
B. Unknown material		
C. Copper		
D. Cast iron (ductile pipe)		
E. Ductile iron		
F. Galvanized steel		
G. Polyvinyl chloride (PVC)		
H. Polyethylene (PE)		
I. High density polypropylene (HDPE)		
J. Polybutylene (PB)		
K. Transite/asbestos cement		
<u>L. Other materials not listed above:</u>		
Identify material 1		
Identify material 2		
Identify material 3		
Identify material 4		
Total number of service connections inventoried* (calculated field)		
Total number of service connections from Section 3 of the EAR		
Lead gooseneck or pigtail components:		
M. <u>NOT</u> on a lead pipe		
N. <u>ON</u> a lead pipe		
Total number of lead service lines** (calculated field)		

*Total number of service connections inventoried (calculated field) = Sum of A through L

**Total number of lead service lines (calculated field) = Sum of A and M

B. METHOD(S) USED TO PREPARE THE LEAD SERVICE LINE INVENTORY IN PART A (CHECK ALL THAT APPLY:

- ☐ Tap Cards or tickets from initial service installation
- ☐ Plans from water main installation, rehabilitation, and replacement Records indicating when buildings were constructed
- ☐ Meter replacement records Distribution maps, drawings, or GIS
- ☐ Visual confirmation of pipe material by plumbers or utility crews during maintenance or installation activities
- ☐ Interviews with water system personnel and/or past employees
- ☐ Field investigations
- ☐ Other _____

C. PRINT THIS INVENTORY FORM FOR YOUR SIGNATURE

I certify under penalty of perjury under the laws of the State of California that the foregoing [including any uploaded documents] is true and correct.

Signature: _____

Name: _____

Title: _____

Phone number: _____

Date signed: _____ (MM/DD/YYYY)

PWS Name: _____ PWS No.: _____

A signed inventory form and map(s) identifying areas with lead service lines or service lines constructed of unknown material will be needed.